



Greater China



Certificate

about the energy efficiency
of escalators according to ISO 25745-3:2015

TÜV SÜD Certification and Testing (China) Co., Ltd. Shanghai Branch
3-13F, No.151 Heng Tong Road
Shanghai, 200070 P.R.China
attests the certificate holder

SJEC Corporation
28 Weixin Road, Ecological Hub, SIP,
Suzhou, China

that the escalator facility hereinafter called
is permitted to be labeled with the
energy efficiency class as followed:

Manufacturer: SJEC Corporation 28 Weixin Road, Ecological Hub, SIP, Suzhou, China Test location: Factory of SJEC Corporation Fengting Road, SIP, Suzhou, China Model: FES Serial no. 14J70009 Type: Escalator	Energy efficiency class  <p>A+++ ≤ 55% A++ ≤ 60% A+ ≤ 65% A ≤ 70% B ≤ 80% C ≤ 90% D ≤ 100% E > 100%</p> <p>A+++</p>
Lifting height: 6.5 m Inclination: 30° Nominal speed: 0.5 m/s Step width: 1000 mm Drive mode: VVVF Motor power: 11 kW Year of manufacture: 2014 Reference: ISO 25745-3:2015	Operation Mode  <p>Power off ✓ Auto start ✓ Slow speed ✓</p>

This certificate is valid until the next modification of the escalator,
but no longer than 2020-08-19

Certificate registry number: 15.07.5010098141.008
Shanghai, 2015-08-20

Certification Office for Energy Efficiency of Lifts


 Wang Peng
